

FIRE & RESCUE SERVICE LICENSE

L.Dis. No.6117/C1/2024

Date:16.12.2024

O/o District Officer,
Fire and Rescue Services,
Thanjavur District, Thanjavur.

Fire License is hereby granted under section 13 of the Tamil Nadu Fire Service Act 1985, Tamil Nadu Fire Service Rules 1990 Appendix III, National Building Code of India Part-IV, Fire and Life Safety 2016, and Tamil Nadu Combined Development and Building Rules 2019, G.O.Ms.No.18, Date:04.02.2019, for online application **HOME-FRSD-THANJAVUR-0902-2024**, Date:09.12.2024, to run a **College** in the name of "**RAJAGIRI DAWOOD BATCHA COLLEGE OF ARTS & SCIENCE**" within the jurisdiction of **Papanasam** Municipality / Panchayat / Corporation at the Premises S.F.Nos.200/2, 201/1B, 1C, 202/1A, 1B, 207/2, 209/1, 2 at Ariyapuram village & S.F. Nos. 1/1, 3, 3/5 at Thiruvaiyathukudi village, Saliyamangalam Road, Papanasam Taluk, Thanjavur District Subject to the condition noted there on and such conditions as may be prescribed. This premise was inspected by District Officer, Fire and Rescue Service, Thanjavur on 16.12.2024.

CONDITIONS

- 1 Firstaid Hose reel System, Manually operated Electric Fire Alarm system should be provided.
- 2 All the Fire Extinguishers have to be recharged and maintained periodically as per code practice in 2190 / 2010.
- 3 All fixed installation should be maintained properly as per NBC-2016.
- 4 Register of Fire Extinguisher and Register of Mock drill should be maintained as per form II & III respectively.
- 5 (off site emergency) Mock drill should be conducted every year.
- 6 Elementary Fire Fighting training should be given to the employee's from Fire Service Department.
- 7 A Board bearing the phone number of the Fire & Rescue Station number should be displayed in the premises.
- 8 House Keeping should be neat and clean.
- 9 Non compliance of the above conditions invites the automatic cancellation of this License.
- 10 In Compliance to section 3.2 of BIS 12459:1988-code of practice for Fire Safety in cable regularization, a transparent fire retardant coating of 1 meter shall be applied on all electrical cables at both sides of termination points in every electrical panel and all the cables in the distribution box.

(Office Seal with Date)



[Handwritten Signature]
District Officer,
Fire and Rescue service,
Thanjavur District, Thanjavur.

[Handwritten Signature]
16/12

To. The Correspondent,
Rajagiri Dawood Batcha College of Arts and Science,
Papanasam.